



7  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No.F.6/DFS/MS/2022/NDZ/ 869

Dated: 10/8/2022

**FIRE SAFETY CERTIFICATE**

Certified that the ST. ANDREWS SCOTS SR. SEC. SCHOOL located at 9th Avenue I.P. Extension, Patparganj, Delhi-110092, building comprised of Ground + Three upper Floors only owned / occupied by ST. ANDREWS SCOTS SR. SEC. SCHOOL, was issued FSC vide letter No. F6/DFS/MS/School/2018/NDZ/1446 Dt. 20/06/2018. The School building was re-inspected by the officer concerned of this department on 01.08.2022 in presence of Sh. K. L. Malhotra (Incharge) and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 10/8/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 10/8/22 at New Delhi by.

  
(S.K. DUA)

**DY. CHIEF FIRE OFFICER.**

Copy to :-

1. The Principal, St. Andrews Scots Sr. Sec. School, 9th Avenue Extension, Patparganj, Delhi-110092.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. Temporary structure/room on terrace should not be used for school purpose.
2. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).

Principal   
St. Andrews Scots Sr. Sec. School  
I.P. Extn. (Patparganj), Delhi-92